



District Level Water Analysis Laboratory

UP Jal Nigam (Rural), Bulandshahr

TEST REPORT

UTR NO:	:	T 9249		
Sample receipt Date:	:	24/03/2025		
Customer/Party Name	:	R.K. PUBLIC SCHOOL, SURAJPUR TEEKRI, SYANA ROAD, AURANGABAD BULANDSHAHR		
Address	:	SURAJPUR TEEKRI, SYANA ROAD, AURANGABAD BULANDSHAHR - 203001		
Contact No.	:	9719204949		
Date of Sampling	:	24/03/2025	Sample Code: 49	
Sample Description	:	24/03/2025		
Quantity	:	1		
Packing details	:			
Analysis Start	:	25/03/2025		
Analysis End	:	25/03/2025		
Water Sample Provided By Upasana Sharma				
Availability of Equipments:		Availability of reference standards:	Adequacy of sample quantity	01
Availability of Test method:	IS 3025	Availability of Trained person:	Duration of testing/Time of Report release	12.35p m

TEST PARAMETER

S. N.	Test Parameters	Method	Specification		Result	(Unit)
1	pH	IS 3025 (Part 11):2017	6.5-8.5	No Relaxation	7.384	-
2	Turbidity	IS 3025 (Part 10):2017	1.0	5.00	1.167	(NTU)*
3	TDS	IS 3025 (Part 16):2017	500	2000	529.2	(Mg/L)*
4	Chloride	IS 3025(Part 32): 2019	250	1000	58	(Mg/L)*
5	Total Alkalinity	IS 3025 (Part 23):1986	200	600	452	(Mg/L)*
6	Total Hardness	IS 3025 (Part 21):2019	200	600	456	(Mg/L)*
7	Colour	APHA 23 rd Edistion	5	15	14	Hazen
8	Taste	IS 3025 (Part 8) : 2017	Agreeable	Qualitative	Agreeable	Qualitative
9	Odour	IS 3025 (Part): 2018	Agreeable	Agreeable	Agreeable	Agreeable
10	E-Coli		0.0	No Relaxation	0.0	-

Reviewed By

G. Singh
Principal
R.K. Public School
(Block Jahangirabad)
Near Police Station
Aurangabad (Bulandshahr)

Sumit
Manager
R.K. Public School
(Block Jahangirabad)
Near Police Station
Aurangabad (Bulandshahr)



Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 25.03.2025

It is certified that an inspection team headed by Dr. Tahsin Raza, medical officer

PHED (Name of Officers with designation) from PHED

inspected the R.K. Public School, Surajpur Teekri, Siyana Road, Aurangabad, Bulandshahr.

(Name & Address of the school) on 24.03.2025 (date of inspection) and on the basis of Water Test

Report (Attached) bearing no. T9249 dated 25.03.2025 Of District Level Water Testing Laboratory,

UP Bulandshahr (PHED Lab) certified that the R.K. Public School, Surajpur Teekri, Siyana Road,

Aurangabad, Bulandshahr. (Name of school) has safe drinking water facilities for the students and

members of staff of the institution. School also maintains the hygienic sanitation condition in the

school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 yr. only.

Signature with Seal: Medical Officer
G. H. C. Lakshmi
Name: Dr. Tahsin Raza
Designation: M.O.
Name & Address of the Office / Department: PHED

To

R.K. Public School,
Surajpur Teekri, Siyana Road
Aurangabad, Bulandshahr, U.P.- 203001
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Principal
R.K. Public School
(Block Jahangirabad)
Near Police Station

Manager
R.K. Public School
(Block Jahangirabad)
Near Police Station
Aurangabad (Bulandshahr)